



**OFFICE OF THE CLERK  
OF THE LEGISLATIVE ASSEMBLY**

PO Box 1866 Apia Samoa - T: (685) 21811 F: (685) 21817 E: ocla@palemene.ws W: www.palemene.ws



**SAMOA PARLIAMENT COMPLEX REDEVELOPMENT PROJECT**

**ADDENDUM 01 : 22 July 2022**

**Procurement Activity: Retender : Engineering, Supply, Installation and Commissioning of Samoa Parliament House Standby Generator**

**Tender: SAM PARLIAMENT 2022**

We wish to advise all Bidders that the following amendment applies to the above Request for Tender (RFT).

With respect to the RFT document :

**Section VI – Schedule of Technical Requirements**

**Section 3. Technical Specifications**

**Scope of Work by Contractor**

1. Item c. is to be amended and read as follows :

*c. Consumable spares parts for generator and other electrical spares, including but not necessarily limited to filters, coolant, belts, hoses, etc. The Supplier shall itemise the spare parts (items and quantity) included in the bid.*

2. **Warranty and Technical Support** is to be amended and read as follows :

Item	Equipment	Technical Specification
1	350kVA (Prime) 385kVA (Standby)	

3. The following narration regarding the **Diesel Engine and Control Battery & Battery Charger** is to be amended and read as follows :

Diesel Engine		
	Rotational Speed	1500 rpm
	Continuous kVA rating at specified site conditions	350 kVA
	Starting method	12/24VDC Electric starting motor
	Fuel	Grade A1 distillate fuel
	Fuel Tank Capacity	Sufficient to run generator for minimum 12 hours.

Control Battery & Battery Charger		
	Supply conditions	240 volts ± 6% single phase
	Frequency	50 ± 1 Hz
	Voltage	12/24 VDC
	Autonomy at specified conditions and load	8 hours

The following narration is **to be deleted** from the RFT.

*RS422 Modbus
*SNMP
*Proprietary PC based monitoring system
The monitoring system shall provide as a minimum the following functionality
*Dynamic updated engine and alternator data
*Alarm management
*Trending of key parameters
PC system shall be provided incorporating a base unit, LCD monitor, keyboard, mouse and shall include all software and licenses
Laminated plastic engraved nameplates shall be provided. Identification nameplates shall be with black lettering on a white background, caution nameplates shall be yellow with black letters and warning nameplates shall be red with white letters and shall be fitted to the front of the switchboard. They shall be of adequate size to permit easy recognition of the circuit. All labels, other than the above, shall be fixed using hammer drive rivets. Self-adhesive labels are not acceptable.

4.

<b>Tender No.</b>	<b>3B. Goods Specifications Compliance Schedule</b>
-------------------	---

The following narration of items in the table (3B. Goods Specifications Compliance schedule) specific to the controller is **to be deleted**.

*RS422 Modbus
*SNMP
*Proprietary PC based monitoring system
The monitoring system shall provide as a minimum the following functionality
*Dynamic updated engine and alternator data
*Alarm management
*Trending of key parameters
PC system shall be provided incorporating a base unit, LCD monitor, keyboard, mouse and shall include all software and licenses
Laminated plastic engraved nameplates shall be provided. Identification nameplates shall be with black lettering on a white background, caution nameplates shall be yellow with black letters and warning nameplates shall be red with white letters and shall be fitted to the front of the switchboard. They shall be of adequate size to permit easy recognition of the circuit. All labels, other than the above, shall be fixed using hammer drive rivets. Self-adhesive labels are not acceptable.

---

All other terms and conditions of the RFT remain unchanged.

All enquiries regarding this RFT or this addendum should be directed in writing to the contact officer nominated in the RFT document.